

Common clarifications Part-1

Technical queries

| SI No | Page | Point | Point description | Clarification |
|-------|------|--------|--|---|
| 1 | 33 | 1.1.2 | Relay should comply to standards: IEC60255, IS 8686, IS 3231, IS 3842 | Numerical relay complying to IEC standards. Is also acceptable |
| 2 | 33 | 1.1.3 | Relay should be Conformal coated and suitable for operation in harsh weather environment and temperature min. 65 °C | The Relays should confirm to following operating conditions: Operation temperature range : -25 – 55°C Storage temperature range: -25 – 70°C |
| 3 | 34 | 1.1.9 | Relay shall store records for last 1000 events(minimum) | Relays shall store last 500 events (minimum) |
| 4 | 35 | 1.1.11 | BRPL PO number and Date must be mentioned on front facia of Relay | Sticker duly depicting PO No & date is acceptable. The sticke should be weather and skretch resistant and have minimum life expectancy up to warranty period. |
| 5 | 41 | 1.7.5 | Low impedance Biased Line Differential Protection of Two and Three End(T) Line feeder using Dual redundant FO Communication channel. | Additional clarifications The communication channel should be suitable for Single mode |

| | | | | |
|---------------------------|---|---|--|---|
| 6 | | | | Installation & testing is not in bidders scope. How ever if there are are issues related to relay configuration then OEM support should be extended with out any cost implication |
| Commercial queries | | | | |
| 1 | 8 | 3 | <p>SCOPE OF WORK</p> <p>The scope shall include Design, Manufacture, supply, Testing & Commisioning at works, conforming to the Technical Specifications enclosed along with Packing, Forwarding, Freight and Unloading and proper stacking at Purchaser's stores. Mainly it is supply as per specifications.</p> | <p>Tender is for Supply of Items as per Annexure-III, Commissioning of items are not a part of tender.</p> |

| | | | | |
|---|----|------------|---|--|
| 2 | 18 | B.1 | <p>EXAMINATION OF SITE AND LOCAL CONDITIONS:</p> <p>The contractor is deemed to have visited the site of the work and ascertained therefore all site conditions and information pertaining to his work. The company shall not accept any claim whatsoever arising out of the difficult site/terrain/local conditions, if any.</p> | <p>As this Tender is for supply portion only and Qty of items are mentioned in Tender, Site Visit is not required.</p> |
| 3 | 19 | 4.04A | <p>The unit rates finalized are also inclusive of barricading and watch & ward during execution and no separate charges shall be paid for the same.</p> | <p>Delivery of Material shall be done at BRPL Stores in one full lot. Any scope related to barricading and watch & ward is not a part of bidder.</p> |
| 4 | 27 | Section-IV | <p>Lot#1: Required by 1st week of Dec'21, Lot#2: Required by 1st week of March'22</p> | <p>Lot-1 deliveries shall be 8- 12 weeks from PO. Lot-2 deliveries shall be as per specification requirements.</p> |

| | | | | |
|---|----|-----|---|--|
| 5 | 18 | 8.1 | <p>EXAMINATION OF SITE AND LOCAL CONDITIONS: The contractor is deemed to have visited the site of the work and ascertained therefore all site conditions and information pertaining to his work. The company shall not accept any claim whatsoever arising out of the difficult site/terrain/local conditions, if any.</p> | <p>As this Tender is for supply portion only and Qty of items are mentioned in Tender, Site Visit is not required.</p> |
|---|----|-----|---|--|