

**CORRIGENDUM -2 FOR NIT: NIT NO CMC/BR/22-23/RB/PR/KG/1053 DT 06.08.2022\_Survey, Design, Supply, Installation, Testing & Commissioning of 33 kV GIS Switching Substation on Single point responsibility basis at Okhla, New Delhi**

**CORRIGENDUM DATE: 13<sup>th</sup> Sep 2022**

| <b>Sl. No.</b> | <b>Clause no.</b>  | <b>Clause Description</b>  | <b>Revised</b>  |
|----------------|--|--|---|
| 1              | Clause no 2.1, Volume-1, Chapter General Design Criteria | 33KV GIS Panels including line side isolator with earthing arrangement (as per Main SLD no BRPL-DJB-STP-DEE-B-0000)" | The GIS Equipment without Line Side Isolator is acceptable to us. However a suitable Outdoor Isolator Arrangement (with earth link) against each panel shall be in the scope of subject bid." |
| 2              | Section-I RFQ clause no 1.02                             | Due date for Bid submission  | Due date for bid submission has been extended up to 19.09.2022  |