## **GOVERNMENT OF NATIONAL CAPITAL TERRITORY OF DELHI** HEADQUARTERS: DELHI FIRE SERVICE: NEW DELHI 110001

No. F.6/DFS/MS/2019 / 5569

Dated: 13/9/19

To

1. The Chief Executive Officer Tata Power Delhi Distribution Limited NDPL House Hudson Lane Kingsway Camp, Delhi-09

13/09/2019

2. The Chief Executive Officer BSES Raidhani Power Limited Shakti Kiran Building Kingsway Camp, Delhi-09

Olo Secretary (Power) GNCTD Diary No....2483

The Chief Executive Officer BSES Yamuna Power Ltd BSES Bhawan, Nehru Place, New Delhi

Date 18 09 149

Sub: Regarding fire incidents occurred in electric meter Board/, distribution boards boards

Sir.

You may be aware that in the recent past many fire incidents have occurred in the electric meter boards/ distribution boards in various parts of the capital city. In each of these incidents, it is observed that the location of electric meter boards/ distribution boards were very close to the means of escape i.e. staircases or corridors, stilts etc. and these were full of smoke, making the evacuation of occupants largely impossible. In some of cases, it was also observed that electric supply was anot automatically switched off and the cables were continuously sparking, even after a considerable period of time, emanating a thick black smoke. This caused a dropping of the visibility to a minimum level. Furthermore, the bunches of cables were also seen hanging haphazardly. Accordingly it is strongly felt that the installation of these energy supply points and equipments may be shifted to a place at a safer distance from the means of escapes in order to save the precious lives and minimize the damage to the property.

In view of above, it is requested to kindly take a note of the aforesaid circumstances and take appropriate decision/ action under intimation to this department in the larger interest of public safety.

Yours faithfully

Director

Ph. 011 - 23414000

Copy to:

The OSD to Secretary (Power) Govt. of NCT of Delhi, Delhi Secretariat, New Delhi

secretary (Rowers)