



## **Tender Notification for**

**RATE CONTRACT FOR SUPPLY OF 11KV XLPE  
INSULATED ALUMINIUM CONDUCTOR AB CABLE OF  
SIZE 3Cx150 AND 1CX95 SQ.MM**

**NIT NO CMC/BR/23-24/RB/PR/FH/1093  
DT 25.01.2023**

**Due Date for Bid Submission: 14.02.2023 1530HRS**

**BSES RAJDHANI POWER LIMITED,  
BSES Bhawan, Nehru Place, New Delhi-110019 Corporate Identification Number:  
U74899DL2001PLC111527 Telephone Number: +91 11 3999 7235  
Fax Number: +91 11 2641 9833  
Website: [www.bsedelhi.com](http://www.bsedelhi.com)**



## **SECTION – I: REQUEST FOR QUOTATION**

### **Event Information**

BRPL invites sealed tenders in 2 envelopes for **RATE CONTRACT FOR SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 3Cx150 AND 1CX95 SQ.MM** from reputed manufacturers. The bidder must qualify the technical requirements as specified in clause 2.0 stated below. All envelopes shall be duly super scribed as **"RATE CONTRACT FOR SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 3Cx150 AND 1CX95 SQ.MM, "NIT No- CMC/BR/23-24/RB/PR/FH/1093, DT 25.01.2023"**

<b>Sl. No.</b>	<b>Item Description</b>	<b>Technical Specification</b>	<b>Estimated Cost</b>	<b>Qty.</b>	<b>Delivery at</b>
1	SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 3Cx150 SQ.MM	BSES-TS-14-HTAB-R0	Rs 1.54 Crores	15 KM	New Delhi Stores
2	SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 1CX95 SQ.MM		Rs 1.46 Crores	35 KM	New Delhi Stores

Note: - The rates quoted shall remain valid for one year from the date of LOI/RC

**Note: Individual Drum Quantity may vary  $\pm 5\%$ . There will be no positive tolerance on the overall total order quantity. However (-) 2% will be allowed on overall order quantity.**

The schedule of specifications with detail terms & conditions can be obtained from address given below against submission of non-refundable demand draft of **Rs.1180/- (With GST)** drawn in favour of BSES Rajdhani Power Ltd, payable at Delhi. The tender documents & detail terms and conditions can also be downloaded from the website **"www.bsedelhi.com --> Tenders --> BSES Rajdhani Power Ltd --> Open Tenders"**.

In case tender papers are downloaded from the above website, then the bidder has to enclose a demand draft covering the cost of bid documents.

The bids shall be addressed to:

Head of Department  
Contracts & Materials Deptt. BSES Rajdhani Power  
Ltd. C&M Deptt.  
1<sup>st</sup> Floor, C Block  
BSES Bhawan, Nehru Place  
New Delhi 110019

BRPL reserves the right to accept/reject any or all Tenders without assigning any reason thereof and alter the quantity of materials mentioned in the Tender documents by ( $\pm$ ) 30% at the time of placing purchase orders.

Tender will be summarily rejected if:

- **Earnest Money Deposit (EMD)** of value INR **6,00,000/-** is not deposited in shape of Bank Draft/Pay Order/Banker's Cheque/BG drawn in favour of BSES Rajdhani Power Ltd, payable at Delhi.
- The offer does not contain "FOR NEW DELHI" price indicating break-up towards all taxes, duties & freight.
- Complete Technical details are not enclosed.
- Tender is received after due date and time.



## **2.0 Qualification Criteria:-**

The prospective bidder must qualify all of the following requirements to be eligible to participate in the bidding. Bidders who meet following requirements will be considered as Successful bidder and BRPL has a right to disqualify those bidders who do not meet these requirements.

<b>S.No</b>	<b>Qualification Requirement</b>	<b>Documents to be submitted by bidder</b>
1	The bidder should have own manufacturing facility for 11KV or higher voltage grade AB Power Cable since last 3 years.	Cable manufacturing and factory incorporation certificate / Undertaking  The details of manufacturing units, locations and works from where supply against this tender shall be proposed to be furnished.
2	The bidder should have manufacturing capacity of minimum 20 km per month	Installed Capacity Certificate
4	The bidder should have supplied at least 50km of HTAB cable in last 5 years to any utilities/SEB's/PSU's/reputed company (wherein the end user shall be Utility/SEB's/PSU's)	i. Summary list of executed Purchase orders ii. Purchase order copies iii. Material delivery clearance certificate copy or delivery completion certificates or Invoice Copies
5	Performance certificate for minimum 2 year satisfactory performance for HT AB cables supplied in last 7 years from at least two utilities/ SEB's/ PSU's/ reputed company wherein the end user shall be utilities/ SEB's/ PSU's.  In case of bidder has a previous association with BRPL/BYPL for similar product and service, the performance feedback for that bidder by BRPL/BYPL shall only be considered irrespective of performance certificate issued by any third organization.	Performance certificates
6	The Bidder must possess valid ISO 9001:2015 & BIS certification.	copy of Certifications
8	Bidder should have Average Annual Sales Turnover of Rs 100 Crores or more in last three (3) Financial Years ( ie. 2019-20, 2020-21, 2021-22)	Balance Sheet and Duly certified CA certificate to be submitted
9	The Bidder shall submit an undertaking that "No Litigation" is pending with the BRPL or its Group/Associates Companies.	Undertaking
10	An undertaking (self-certificate) that the bidder has not been blacklisted/debarred by any central/state government institution/Electricity utilities	Undertaking
11	The bidder must have valid PAN No., GST Registration Number, in addition to other statutory compliances. The bidder must submit the copy of registrations and submit an undertaking that the bidder shall comply all the statutory compliances as per the laws/rules etc. before the start of the supply/work.	Relevant Statutory Documents Copy/ Undertaking



**NOTE: - For SL NO-4 of qualification criteria data to be submitted as per annexure-VII**

### **3.0 Bidding and Award Process.**

Bidders are requested to submit their offer strictly in line with this tender document. **NO DEVIATION IS ACCEPTABLE.** BRPL shall respond to the clarifications raised by various bidders and the same will be intimated to all participating bidders through website.

#### **BID SUBMISSION**

The bidders are required to submit the bids in 2(two) parts and submitted in 1 original + 1 duplicate to the following address

**Head of Department**  
Contracts & Material Deptt.  
BSES Rajdhani Power Ltd 1<sup>st</sup> Floor,  
C Block, BSES Bhawan, Nehru Place New Delhi  
110019

#### **PART A: TECHNICAL BID** comprising of following (in duplicate)

EMD  
Non-refundable demand draft for Rs 1180/- in case the forms are downloaded from website  
Documentary evidence in support of qualifying criteria  
Technical Literature/ GTP/Type test report etc  
Qualified Manpower available Testing Facilities  
Original Tender documents duly stamped & signed on each page as token of acceptance  
Acceptance to Commercial Terms and Conditions viz Delivery schedule/period, Payment terms, BG etc  
Power of Attorney for signing the bid

#### **PART B: FINANCIAL BID** comprising (1 original only)

- ✓ Price strictly in the Format enclosed in SECTION V indicating Break up of basic price, taxes & duties, Freight etc

#### **TIME SCHEDULE**

The bidders should complete the following within the dates specified as under:

<b>S.No.</b>	<b>Steps</b>	<b>Date</b>
1	Date of sale of bid documents	25.01.2023, onwards
2	Last date of Queries, if any	09.02.2023, 1500hrs
3	Last date of receipt of bid documents	14.02.2023, 1500hrs
4	Date & time of opening of tender - Part A	14.02.2023, 1530hrs
5	Date & Time of opening of Part B of qualified bidders	Only Successful bidders

NOTE: In case last date of submission of bids & date of opening of bids is declared as holiday in BRPL office, the last date of submission will be following working day at the same time.

This is a two part bid process. Bidders are to submit the bids in 2(two) parts.

Both these parts should be furnished in separate sealed covers super scribing NIT no. DUE DATE OF SUBMISSION, with particulars as **PART-A TECHNICAL BID & COMMERCIAL TERMS & CONDITIONS** and **Part-B "FINANCIAL BID** and these sealed envelopes should again be placed in another sealed cover which shall be submitted before the due date & time specified.

**Bidders are requested to submit the bid in one Original plus one copy in duplicate**

**Part – A:** Technical Bid should not contain any cost information whatsoever and shall be submitted within the due date.



**PART B:** This envelope will be opened after techno-commercial evaluation and only of the qualified bidders. The Purchaser reserves the right to assess bidder's capability to perform the contract, should the circumstances warrant such assessment in the overall interest of the purchaser. In this regard the decision of the purchaser is final.

**Part –C : E- Bidding and Reverse Auction through SAP-SRM Module**

Purchase reserves the right to use the reverse auction through SAP-SRM tool as an integral part of the entire tendering process. All the bidders who are techno-commercial qualified on the basis of tender requirements shall participate in reverse auction.

Notwithstanding anything stated above, the Purchaser reserves the right to assess bidder's capability to perform the contract, should the circumstances warrant such assessment in the overall interest of the purchaser. In this regard the decision of the purchaser is final.

**BIDS RECEIVED AFTER DUE DATE AND TIME MAY BE LIABLE TO REJECTION**



### **Award Decision**

The purchaser reserves all the rights to award the contract to one or more bidders so as to meet the delivery requirement or nullify the award decision without any reason.

In the event of your bid being selected by purchaser (and / or its affiliates) and you subsequent DEFAULT on your bid; you will be required to pay purchaser (and / or its affiliates) an amount equal to the difference in your bid and the next lowest bid on the quantity declared in NIT/RFQ.

In case any supplier is found unsatisfactory during the delivery process, the award will be cancelled and BRPL reserves the right to award other suppliers who are found fit.

**QTY VARIATION:** The purchaser reserves the rights to vary the quantity by **(±) 30%** of the tender quantity.

**Repeat Order:** BRPL reserves the right to place repeat order at the same rates & terms and conditions as per this tender against additional requirement subject to mutual agreement between BRPL & supplier

### **Market Integrity**

We have a fair and competitive marketplace. The rules for bidders are outlined in the Terms & Conditions. Bidders must agree to these rules prior to participating. In addition to other remedies available, we reserves the right to exclude a bidder from participating in future markets due to the bidder's violation of any of the rules or obligations contained in the Terms & Condition. Bidders who violates the marketplace rules or engage in behavior that disrupts the fair execution of the marketplace restricts a bidder to length of time, depending upon the seriousness of the violation. Examples of violations include, but are not limited to:

- ❖ Failure to honor prices submitted to the marketplace.
- ❖ Breach of the terms of the published in Request for Quotation/NIT.

### **6.0 Supplier Confidentiality**

All information contained in this RFQ is confidential and shall not be disclosed, published or advertised in any manner without written authorization from BRPL. This includes all bidding information submitted.

All RFQ documents remain the property of BRPL and all suppliers are required to return these documents to BRPL upon request.

Suppliers who do not honor these confidentiality provisions will be excluded from participating in future bidding events.

### **7.0 Contact Information**

Technical clarification, if any, as regards this RFQ shall be sought in writing and sent by post/courier to following address. The same shall not be communicated through email/phone

	<b>Technical</b>	<b>Commercial</b>
<b>Contact Person</b>	to CES Copy to : Pankaj Goyal	To:- faiyaz.hussain@relianceada.com Copy to : Pankaj Goyal
<b>Address</b>	BSES RAJDHANI Power Ltd ,5th Floor , 20 No Building, Nehru Place,New Delhi 110019	C&M Deptt. 1st Floor , D-Block, BSES RAJDHANI Power Ltd BSES Bhawan, Nehru Place, New Delhi 110019
<b>Email</b>	Amit.as.tomar@relianceada.com	Pankaj.goyal@relianceada.com



## **SECTION – II: INSTRUCTION TO BIDDERS**

### **A. GENERAL**

#### **1.00**

BSES Rajdhani Power Ltd hereinafter referred to as "The Purchaser "are desirous of implementing the various Systems Improvement/Repair & Maintenance works at their respective licensed area in Delhi. The Purchaser has now floated this tender for procurement of material as notified earlier in this bid document.

#### **2.00 SCOPE OF WORK**

The scope shall include Design, Manufacture, Testing at works conforming to the Technical Specifications/IS along with Packing, Forwarding, Transportation and Unloading and proper stacking at Purchaser's stores/site.

### **DISCLAIMER**

- This Document includes statements, which reflect various assumptions, which may or may not be correct. Each Bidder/Bidding Consortium should conduct its own estimation and analysis and should check the accuracy, reliability and completeness of the information in this Document and obtain independent advice from appropriate sources in their own interest.

- Neither Purchaser nor its employees will have any liability whatsoever to any Bidder or any other person under the law or contract, the principles of restitution or unjust enrichment or otherwise for any loss, expense or damage whatsoever which may arise from or be incurred or suffered in connection with anything contained in this Document, any matter deemed to form part of this Document, provision of Services and any other information supplied by or on behalf of Purchaser or its employees, or otherwise arising in any way from the selection process for the Supply.

- Though adequate care has been taken while issuing the Bid document, the Bidder should satisfy itself that Documents are complete in all respects. Intimation of any discrepancy shall be given to this office immediately.

- This Document and the information contained herein are Strictly Confidential and are for the use of only the person(s) to whom it is issued. It may not be copied or distributed by the recipient to third parties (other than in confidence to the recipient's professional advisors).

#### **4.00 COST OF BIDDING**

The Bidder shall bear all cost associated with the preparation and submission of its Bid and Purchaser will in no case be responsible or liable for those costs.

### **B. BIDDING DOCUMENTS**

The Scope of Work, Bidding Procedures and Contract Terms are described in the Bidding Documents are as follows:

#### **Volume - I**

- Request for Quotation (RFQ) - Section - I
- Instructions to Bidders (ITB) - Section - II
- Terms & Conditions of Contract (T&C) - Section -III
- Delivery schedule - Section IV
- Technical Specifications (TS) - Section V (Pages Enclosed)



## Volume - II

- Price Format - Annexue -I
- Bid Form - Annexure -II
- Acceptance Form for Reverse Auction - Annexure -III
- EMD BG Format - Annexure -IV
- Commercial Terms & Conditions- Annexure -V
- No Deviation Sheet - Annexure -VI

**5.00** The Bidder is expected to examine the Bidding Documents, including all Instructions, Forms, Terms and Specifications. Failure to furnish all information required by the Bidding Documents or submission of a Bid not substantially responsive to the Bidding Documents in every respect will may result in the rejection of the Bid.

### **AMENDMENT OF BIDDING DOCUMENTS**

**6.01-** At any time prior to the deadline for submission of Bids, the Purchaser may for any reasons, whether at its own initiative or in response to a clarification requested by a prospective Bidder, modify the Bidding Documents by Amendment.

**6.02-** The Amendment shall be part of the Bidding Documents, pursuant to Clause 6.01, and it will be notified in web site [www.bsesdelhi.com](http://www.bsesdelhi.com) and the same will be binding on them.

- In order to afford prospective Bidders reasonable time in which to take the Amendment into account in preparing their Bids, the Purchaser may, at its discretion, extend the deadline for the submission of Bids. The same shall be published as a corrigendum in website [www.bsesdelhi.com](http://www.bsesdelhi.com)

- Purchaser shall reserve the rights to following

- extend due date of submission
- modify tender document in part/whole
- cancel the entire tender

**Bidders are requested to visit website regularly for any modification/clarification/corrigendum/addendum of the bid documents.**

## **C. PREPARATION OF BIDS**

### **7.0 LANGUAGE OF BID**

The Bid prepared by the Bidder, and all correspondence and documents relating to the Bid exchanged by the Bidder and the Purchaser, shall be written in the English Language. Any printed literature furnished by the Bidder may be written in another Language, provided that this literature is accompanied by an English translation, in which case, for purposes of interpretation of the Bid, the English translation shall govern.

### **DOCUMENTS COMPRISING THE BID**

The Bid prepared and submitted by the Bidder shall comprise the following components:



Bid Form, Price & other Schedules (STRICTLY AS PER FORMAT) and Technical Data Sheets completed in accordance with Technical Specification.

All the Bids must be accompanied with the required EMD as mentioned in the Section-I against each tender.

Tender documents duly stamped and signed on each page by authorized signatory.

## 9.0 BID FORM

The Bidder shall submit one "Original" and one "Copy" of the Bid Form and the appropriate Price Schedules and Technical Data Sheets duly filled in as per attached specification (Section VIII) enclosed with the Bidding Documents.

### EMD

Pursuant to Clause 8.0(b) above, the bidder shall furnish, as part of its bid, a EMD amounting to as specified in the Section-I. The EMD is required to protect the Purchaser against the risk of Bidder's conduct which would warrant forfeiture.

The EMD shall be denominated in any of the following form:

Banker's Cheque/Demand Draft/Pay Order drawn in favour of BSES Rajdhani Power Ltd, payable at Delhi.

A bank guarantee issued by any scheduled bank strictly as per the format enclosed and shall be valid for a period of thirty (30) days beyond the validity of the bid

The EMD may be forfeited in case of:

- ✓ the Bidder withdraws its bid during the period of specified bid validity

or

- ✓ the case of a successful Bidder, if the Bidder does not
  - accept the Purchase Order, or
  - Furnish the required performance security BG.

### BID PRICES

- Bidders shall quote for the entire Scope of Supply with a break-up of prices for individual items. The total Bid Price shall also cover all the Supplier's obligations mentioned in or reasonably to be inferred from the Bidding Documents in respect of Design, Supply, Transportation to site, all in accordance with the requirement of Bidding Documents. The Bidder shall complete the appropriate Price Schedules included herein, stating the Unit Price for each item & total Price.

- The prices offered shall be inclusive of all costs as well as Duties, Taxes and Levies paid or payable during execution of the supply work, breakup of price constituents, should be there.

Prices quoted by the Bidder shall be "**Firm**" during the performance of the Contract.



#### **11.0 BID CURRENCIES**

Prices shall be quoted in Indian Rupees Only.

#### **12.0 PERIOD OF VALIDITY OF BIDS**

**12.01-** Bids shall remain valid for 120 days from the due date of submission of the Bid.

**12.02** -Notwithstanding Clause 12.01 above, the Purchaser may solicit the Bidder's consent to an extension of the Period of Bid Validity. The request and the responses thereto shall be made in writing and sent by post/courier

#### **13.0 ALTERNATIVE BIDS**

Bidders shall submit Bids, which comply with the Bidding Documents. Alternative Bids will not be considered. The attention of Bidders is drawn to the provisions regarding the rejection of Bids in the terms and conditions, which are not substantially responsive to the requirements of the Bidding Documents.

#### **14.0 FORMAT AND SIGNING OF BID**

The original Bid Form and accompanying documents (as specified in Clause 9.0), clearly marked "Original Bid" plus one copy must be received by the Purchaser at the date, time and place specified pursuant to Clauses 15.0 and 16.0. In the event of any discrepancy between the original and the copies, the original shall govern.

The original and copy of the Bid shall be typed or written in indelible ink and shall be signed by the Bidder or a person or persons duly authorized to sign on behalf of the Bidder. Such authorization shall be indicated by written Power-of-Attorney accompanying the Bid.

**14.02** The Bid shall contain no interlineations, erasures or overwriting except as necessary to correct errors made by the Bidder, in which case such corrections shall be initialed by the person or persons signing the Bid.

#### **D. SUBMISSION OF BIDS**

#### **15.0 SEALING AND MARKING OF BIDS**

Bid submission: One original & one Copy (hard copies) of all the Bid Documents shall be sealed and submitted to the Purchaser before the closing time for submission of the bid.

The Technical Documents and the EMD shall be enclosed in a sealed envelope and the said envelope shall be super scribed with —"**Technical & EMD**". The price bid shall be inside another sealed envelope with super scribed as "Financial Bid". Both these envelopes shall be sealed inside another big envelope. All the envelopes should bear the Name and Address of the Bidder and marking for the Original and Copy. The envelopes should be super scribed with —"Tender Notice No & Due date of opening".

The Bidder has the option of sending the Bids in person. Bids submitted by Email/Telex/Telegram /Fax will be rejected. No request from any Bidder to the Purchaser to collect the proposals from Courier/Airlines/Cargo Agents etc shall be entertained by the Purchaser.



## **16.0 DEADLINE FOR SUBMISSION OF BIDS**

The original Bid, together with the required copies, must be received by the Purchaser at the address specified no **later than the due date specified earlier**

The Purchaser may, at its discretion, extend the deadline for the submission of Bids by amending the Bidding Documents in accordance with Clause 9.0, in which case all rights and obligations of the Purchaser and Bidders previously subject to the deadline will thereafter be subject to the deadline as extended

## **17.0 ONE BID PER BIDDER**

Each Bidder shall submit only one Bid by itself. No Joint Venture is acceptable. A Bidder who submits or participates in more than one Bid will cause all those Bids to be rejected.

## **18.0 LATE BIDS**

Any Bid received by the Purchaser after the deadline for submission of Bids prescribed by the Purchaser, pursuant to Clause 16.0, will be declared "Late" and may be rejected and returned unopened to the Bidder.

## **19.0 MODIFICATIONS AND WITHDRAWAL OF BIDS**

The Bidder is not allowed to modify or withdraw its Bid after the Bid's submission.

### **E. EVALUATION OF BID**

## **20.0 PROCESS TO BE CONFIDENTIAL**

Information relating to the examination, clarification, evaluation and comparison of Bids and recommendations for the award of a contract shall not be disclosed to Bidders or any other persons not officially concerned with such process. Any effort by a Bidder to influence the Purchaser's processing of Bids or award decisions may result in the rejection of the Bidder's Bid.

## **21.0 CLARIFICATION OF BIDS**

To assist in the examination, evaluation and comparison of Bids, the Purchaser may, at its discretion, ask the Bidder for a clarification of its Bid. All responses to requests for clarification shall be in writing and no change in the price or substance of the Bid shall be sought, offered or permitted.

## **22.0 PRELIMINARY EXAMINATION OF BIDS / RESPONSIVENESS**

Purchaser will examine the Bids to determine whether they are complete, whether any computational errors have been made, whether required sureties have been furnished, whether the documents have been properly signed, and whether the Bids are generally in order. Purchaser may ask for submission of original documents in order to verify the documents submitted in support of qualification criteria.

Arithmetical errors will be rectified on the following basis. If there is a discrepancy between the unit price and the total price per item that is obtained by multiplying the unit price and quantity, the unit price shall prevail and the total price per item will be corrected. If there is a discrepancy between the Total Amount and the sum of the total price per item, the sum of the total price per item shall prevail and the Total Amount will be corrected.

Prior to the detailed evaluation, Purchaser will determine the substantial responsiveness of each Bid to the Bidding Documents including production capability and acceptable quality of the Goods offered. A substantially responsive Bid is one, which conforms to all the terms and conditions of the Bidding Documents without material deviation.



Bid determined as not substantially responsive will be rejected by the purchaser and/or the Purchaser and may not subsequently be made responsive by the Bidder by correction of the non - conformity.

### **23.0 EVALUATION AND COMPARISON OF BIDS**

The evaluation of Bids shall be done based on the delivered cost competitiveness basis.

The evaluation of the Bids shall be a stage-wise procedure. The following stages are identified for evaluation purposes: In the first stage, the Bids would be subjected to a responsiveness check. The Technical Proposals and the Conditional ties of the Bidders would be evaluated.

Subsequently, the Financial Proposals along with Supplementary Financial Proposals, if any, of Bidders with Techno-commercially Acceptable Bids shall be considered for final evaluation.

The Purchaser's evaluation of a Bid will take into account, in addition to the Bid price, the following factors, in the manner and to the extent indicated in this Clause:

Delivery Schedule

Conformance to Qualifying Criteria

Deviations from Bidding Documents

Bidders shall base their Bid price on the terms and conditions specified in the Bidding Documents.

The cost of all quantifiable deviations and omissions from the specification, terms and conditions specified in Bidding Documents shall be evaluated. The Purchaser will make its own assessment of the cost of any deviation for the purpose of ensuring fair comparison of Bids.

Any adjustments in price, which result from the above procedures, shall be added for the purposes of comparative evaluation only to arrive at an "Evaluated Bid Price". Bid Prices quoted by Bidders shall remain unaltered.

## **F. AWARD OF CONTRACT**

### **24.0 CONTACTING THE PURCHASER**

If any Bidder wishes to contact the Purchaser on any matter related to the Bid, from the time of Bid opening to the time of contract award, the same shall be done in writing only.

Any effort by a Bidder to influence the Purchaser and/or in the Purchaser's decisions in respect of Bid evaluation, Bid comparison or Contract Award, will result in the rejection of the Bidder's Bid.

### **25.0 THE PURCHASER 'S RIGHT TO ACCEPT ANY BID AND TO REJECT ANY OR ALL BIDS**

Submission of bids shall not automatically construe qualification for evaluation. The Purchaser reserves the right to accept or reject any Bid and to annul the Bidding process and reject all Bids at any time prior to award of Contract, without thereby incurring any liability to the affected Bidder or Bidders or any obligation to inform the affected Bidder or Bidders of the grounds for the Purchaser's action.



## **AWARD OF CONTRACT**

The Purchaser will award the Contract to the successful Bidder whose Bid has been determined to be the lowest-evaluated responsive Bid, provided further that the Bidder has been determined to be qualified to satisfactorily perform the Contract. Purchaser reserves the right to award order to other bidders in the tender, provided it is required for timely execution of project & provided he agrees to come to the lowest rate. Purchaser reserves the right to distribute the entire tender quantity at its own discretion without citing any reasons thereof.

### **Splitting of tendered quantity among two or more bidders:**

BSES reserves the right to split the tender quantity among techno- commercially qualified bidders on account of delivery requirement in tender quantity under procurement.

For arranging timely procurement of material and to have uniform practice of distribution of quantity amongst eligible bidders, following procedure shall be applicable:

The tender quantity shall be split in following ratio:

- (i) If the quantity is to be split among 2 bidders, it will be done in the ratio of 70:30 on L1 price.
- (ii) If the quantity is to be split among 3 bidders, it will be done in the ratio of 60:25:15 on L1 price.

Any deviation in regards to above will have deviation approval from management.

## **27.0 THE PURCHASER 'S RIGHT TO VARY QUANTITIES**

The Purchaser reserves the right to vary the quantity i.e. increase or decrease the numbers/quantities without any change in terms and conditions during the execution of the Order.

## **28.0 LETTER OF INTENT/ NOTIFICATION OF AWARD**

The letter of intent/ Notification of Award shall be issued to the successful Bidder whose bids have been considered responsive, techno-commercially acceptable and evaluated to be the lowest (L1). The successful Bidder shall be required to furnish a letter of acceptance within 7 days of issue of the letter of intent /Notification of Award by Purchaser.

## **29.0 PERFORMANCE BANK GAURANTEE**

The successful Bidder shall furnish the Performance Bank Guarantee for an amount of 10% (Ten percent) of the Contract Price. The Performance Bond shall be valid for a period of 24 months from the date of Commissioning or 30 months from the date of last dispatch whichever is earlier plus 3 months claim period. Upon submission of the performance security, the EMD shall be released.

## **30.0 CORRUPT OR FRADULENT PRACTICES**

**30.01** The Purchaser requires that the Bidders observe the highest standard of ethics during the procurement and execution of the Project. In pursuance of this policy, the Purchaser:

- (a)** Defines, for the purposes of this provision, the terms set forth below as follows:



- "Corrupt practice" means behavior on the part of officials in the public or private sectors by which they improperly and unlawfully enrich themselves and/or those close to them ,or induce others to do so, by misusing the position in which they are placed, and it includes the offering, giving, receiving, or soliciting of anything of value to influence the action of any such official in the procurement process or in contract execution; and
- "Fraudulent practice" means a misrepresentation of facts in order to influence a procurement process or the execution of a contract to the detriment of the Purchaser, and includes collusive practice among Bidders (prior to or after Bid submission) designed to establish Bid prices at artificial non -competitive levels and to deprive the Purchaser of the benefits of free and open competition.

(b) Will reject a proposal for award if it determines that the Bidder recommended for award has engaged in corrupt or fraudulent practices in competing for the contract in question ;

(c) Will declare a firm ineligible, either indefinitely or for a stated period of time, to be awarded a contract if it at any time determines that the firm has engaged in corrupt or fraudulent practices in competing for, or in executing, a contract.

Furthermore, Bidders shall be aware of the provision stated in the Terms and Condition of Contract.

## **SECTION – III: TERMS AND CONDITIONS**

### **1.0 General Instructions**

All the Bids shall be prepared and submitted in accordance with these instructions.

Bidder shall bear all costs associated with the preparation and delivery of its Bid, and the Purchaser will in no case shall be responsible or liable for these costs.

The Bid should be submitted by the Bidder in whose name the bid document has been issued and under no circumstances it shall be transferred /sold to the other party.

The Purchaser reserves the right to request for any additional information and also reserves the right to reject the proposal of any Bidder, if in the opinion of the Purchaser, the data in support of RFQ requirement is incomplete.

The Bidder is expected to examine all instructions, forms, terms & conditions and specifications in the Bid Documents. Failure to furnish all information required in the Bid Documents or submission of a Bid not substantially responsive to the Bid Documents in every respect may result in rejection of the Bid. However, the Purchaser's decision in regard to the responsiveness and rejection of bids shall be final and binding without any obligation, financial or otherwise, on the Purchaser.

#### **Definition of Terms**

"Purchaser" shall mean BSES Rajdhani Power Limited, on whose behalf this bid enquiry is issued by its authorized representative / officers.

"Bidder" shall mean the firm who quotes against this bid enquiry issued by the Purchaser. "Supplier" or "Supplier" shall mean the successful Bidder and/or Bidders whose bid has been accepted by the Purchaser and on whom the "Letter of Acceptance" is placed by the Purchaser and shall include his heirs, legal representatives, successors and permitted assigns wherever the context so admits.

"Supply" shall mean the Scope of Contract as described.



"Specification" shall mean collectively all the terms and stipulations contained in those portions of this bid document known as RFQ, Commercial Terms & Condition, and Instructions to Bidders, Technical Specifications and the Amendments, Revisions, Deletions or Additions, as may be made by the Purchaser from time to time.

"Letter of Acceptance" shall mean the official notice issued by the Purchaser notifying the Supplier that his proposal has been accepted and it shall include amendments thereto, if any, issued by the Purchaser. The "Letter of Acceptance" issued by the Purchaser shall be binding on the "Supplier" The date of Letter of Acceptance shall be taken as the effective date of the commencement of contract.

"Month" shall mean the calendar month and "Day" shall mean the calendar day.

"Codes and Standards" shall mean all the applicable codes and standards as indicated in the Specification.

"Offer Sheet" shall mean Bidder's firm offer submitted to BRPL in accordance with the specification.

"Contract" shall mean the "Letter of Acceptance/Purchase Order" issued by the Purchaser.

"Contract Price" shall mean the price referred to in the "Letter of Acceptance/Purchase Order".

"Contract Period" shall mean the period during which the "Contract" shall be executed as agreed between the Supplier and the Purchaser in the Contract inclusive of extended contract period for reason beyond the control of the Supplier and/or Purchaser due to force Majeure.

"Acceptance" shall mean and deemed to include one or more of the following as will be stipulated in the specification:

- a) The written acceptance of material by the inspector at suppliers works to ship the materials.
- b) Acceptance of material at Purchaser site stores after its receipt and due inspection/ testing and release of material acceptance voucher.
- c) Where the scope of the contract includes supply, acceptance shall mean issue of necessary equipment / material takeover receipt after installation & commissioning and final acceptance.

### **3.0 Contract Documents & Priority**

3.01 Contract Documents: The terms and conditions of the contract shall consist solely of these RFQ conditions and the offer sheet.

### **4.0 Scope of Supply -General**

The "Scope of Supply" shall be on the basis of Bidder's responsibility, completely covering the obligations, responsibility and supplies provided in this Bid enquiry whether implicit or explicit.

Bidder shall have to quote for the Bill of quantities as listed in Section – IV of this RFQ.

Quantity variation and additional requirement if any shall be communicated to successful bidder during project execution.

All relevant drawings, data and instruction manuals.



## 5.0 Quality Assurance and Inspection

Immediately on award of contract, the bidder shall prepare detailed quality assurance plan / test procedure identifying the various stages of manufacture, quality checks performed at each stage, raw material inspection and the Customer hold points. The document shall also furnish details of method of checking, inspection and acceptance standards / values and get the approval of Purchaser before proceeding with manufacturing. However, Purchaser shall have right to review the inspection reports, quality checks and results of suppliers in house inspection department which are not Customer hold points and the supplier shall comply with the remarks made by purchaser or his representative on such reviews with regards to further testing, rectification or rejection, etc. In case of standard items, BRPL shall forward the standard QAP which is to be follow by vendor during manufacturing.

Witness and Hold points are critical steps in manufacturing, inspection and testing where the supplier is obliged to notify the Purchaser in advance so that it may be witnessed by the Purchaser. Final inspection is a mandatory hold point. The supplier to proceed with the work past a hold point only after clearance by purchaser or a witness waiver letter from BRPL.

The performance of waiver of QA activity by Purchaser at any stage of manufacturing does not relieve the supplier of any obligation to perform in accordance with and meet all the requirements of the procurement documents and also all the codes & reference documents mentioned in the procurement document nor shall it preclude subsequent rejection by the purchaser.

On completion of manufacturing the items can only be dispatched after receipt of dispatch instructions issued by the Purchaser.

All in-house testing and inspection shall be done without any extra cost. The in-house inspection shall be carried out in presence of BSES/BSES authorized third party inspection agency. Cost of Futile/abortive visit(s) shall be debited from the invoices.

Purchaser reserves the right to send any material being supplied to any recognized laboratory for testing, wherever necessary and the cost of testing shall be borne by the Bidder. In case the material is found not in order with the technical requirement / specification, the charges along with any other penalty which may be levied is to be borne by the bidder. To avoid any complaint the supplier is advised to send his representative to the stores to see that the material sent for testing is being sealed in the presence of bidder's representative.

## 6.0 Packing, Packing List & Marking

**Packing:** Supplier shall pack or shall cause to be packed all Commodities in crates/boxes/drums/containers/cartons and otherwise in such a manner as shall be reasonably suitable for shipment by road or rail to BRPL, Delhi/New Delhi stores/site without undue risk of damage in transit.

**Packing List:** The contents of each package shall be itemized on a detailed list showing the exact weight, extreme outside dimensions (length, width and weight) of each container/box/drum/carton, Item SAP Code, PO No & date. One copy of the packing list shall be enclosed in each package delivered.

## 7.0 Price basis for supply of materials

Bidder to quote their prices on Landed Cost Basis and separate price for each item. **FIRM** for supply to BRPL site/ stores inclusive of packing, forwarding, loading at manufacturer's premises, Freight& GST.



The above supply prices shall also include unloading at BRPL Delhi/New Delhi stores/site.

Transit insurance will be arranged by Purchaser; however bidder to furnish required details in advance for arranging the same by Purchaser.

### **Terms of payment and billing**

For Supply of Equipments:

100% payment shall be made within 45 days from the date of receipt of material at store/ site

Bidder to submit the following documents against dispatch of each consignment:

- i.** Consignee copy of LR
- ii.** Supplier detailed invoice showing commodity description, quantity, unit price, total price and basis of delivery.
- iii.** Original certificate issued by BRPL confirming receipt of material at site and acceptance of the same.
- iv.** Dispatch clearance & inspection report issued by the inspection authority
- v.** Packing List.
- vi.** Test Reports
- vii.** Guarantee Certificate.

### **9.0 Price Validity**

**9.01** All bids submitted shall remain valid, firm and subject to unconditional acceptance by BRPL Delhi as mentioned earlier, the prices shall remain valid and firm till contract completion.

### **10.0 Performance Guarantee**

The bidder shall establish a performance bond in favor of BRPL in an amount not less than ten percent (10%) of the total price of the Contract (the "Performance Bond"). The Performance Bond shall be valid for a period of 24 months from the date of Commissioning or 30 months from the date of last dispatch whichever is earlier plus 3 months claim period.

Bank guarantee shall be drawn in favor of BSES Rajdhani Power Ltd as applicable. The performance Bank guarantee shall be in the format as specified by BRPL.

### **11.0 Forfeiture**

Each Performance Bond established under Clause 10.0 shall contain a statement that it shall be automatically and unconditionally forfeited without recourse and payable against the presentation by BRPL of this Performance Bond, to the relevant bank referred to above, together with a simple statement that supplier has failed to comply with any term or condition set forth in the Contract.

Each Performance BG established under will be automatically and unconditionally forfeited without recourse if BRPL in its sole discretion determines that supplier has failed to comply with any term or condition set forth in the contract.

### **12.0 Release**

All Performance Bonds will be released without interest within seven (7) days from the last date up to which the Performance Bond has to be kept valid (as defined in Clause 10.0) except for the case set forth in Clause 21.0.



### **13.0 Warranty/Defects Liability Period**

**13.01** The bidder to guarantee the materials / items supplied against any defect of failure, which arise due to faulty materials, workmanship or design for the entire defects liability period. The Defect liability period shall be 60 months from the date of commissioning or 66 months from the date of delivery whichever is earlier. If during the defects liability period any materials / items are found to be defective, these shall be replaced or rectified by the bidder at his own cost within 30 days from the date of receipt of intimation.

### **14.0 Return, Replacement or Substitution.**

BRPL shall give Supplier notice of any defective Commodity promptly after becoming aware thereof. BRPL may in its discretion elect to return defective Commodities to Supplier for replacement, free of charge to BRPL, or may reject such Commodities and purchase the same or similar Commodities from any third party. In the latter case BRPL shall furnish proof to Supplier of the cost of such substitute purchase. In either case, all costs of any replacement, substitution, shipping, labor and other related expenses incurred in connection with the return and replacement or for the substitute purchase of a Commodity hereunder should be for the account of Supplier. BRPL may set off such costs against any amounts payable by BRPL to Supplier. Supplier shall reimburse BRPL for the amount, if any, by which the price of a substitute Commodity exceeds the price for such Commodity as quoted in the Bid.

### **15.0 Effective Date of Commencement of Contract:**

**15.01** The date of the issuance of the Letter of Acceptance/Purchase Order shall be treated as the effective date of the commencement of Contract.

### **16.0 Time – The Essence of Contract**

16.01 The time and the date of completion of the "Supply" as stipulated in the Letter of Acceptance / Purchase order issued to the Supplier shall be deemed to be the essence of the "Contract". The Supply has to be completed not later than the aforesaid Schedule and date of completion of supply.

### **17.0 The Laws and Jurisdiction of Contract:**

The laws applicable to this Contract shall be the Laws in force in India.

All disputes arising in connection with the present Contract shall be settled amicably by mutual consultation failing which shall be finally settled as per the rules of Arbitration and Conciliation Act, 1996 at the discretion of Purchaser. The venue of arbitration shall be at Mumbai in India

### **Events of Default**

Events of Default. Each of the following events or occurrences shall constitute an event of default ("Event of Default") under the Contract:

- (a) Supplier fails or refuses to pay any amounts due under the Contract;
- (b) Supplier fails or refuses to deliver Commodities conforming to this RFQ/ specifications, or fails to deliver Commodities within the period specified in P.O. or any extension thereof
- (c) Supplier becomes insolvent or unable to pay its debts when due, or commits any act



of bankruptcy, such as filing any petition in any bankruptcy, winding-up or reorganization proceeding, or acknowledges in writing its insolvency or inability to pay its debts; or the Supplier's creditors file any petition relating to bankruptcy of Supplier;

- (d) Supplier otherwise fails or refuses to perform or observe any term or condition of the Contract and such failure is not remediable or, if remediable, continues for a period of 30 days after receipt by the Supplier of notice of such failure from BRPL.

#### **Consequences of Default.**

- (a) If an Event of Default shall occur and be continuing, BRPL may forthwith terminate the Contract by written notice.
- (b) In the event of an Event of Default, BRPL may, without prejudice to any other right granted to it by law, or the Contract, take any or all of the following actions;
- (i) present for payment to the relevant bank the Performance Bond;
  - (ii) Purchase the same or similar Commodities from any third party; and/or
  - (iii) Recover any losses and/or additional expenses BRPL may incur as a result of Supplier's default.

#### **20.0 Penalty for Delay**

If supply of items / equipments is delayed beyond the supply schedule as stipulated in purchase order then the Supplier shall be liable to pay to the Purchaser as penalty for delay, a sum of 1% (one percent) of the basic (ex-works) price for every week delay or part thereof for individual milestone deliveries.

The total amount of penalty for delay under the contract will be subject to a maximum of ten percent (10%) of the basic (ex-works) price

The Purchaser may, without prejudice to any method of recovery, deduct the amount for such damages from any amount due or which may become due to the Supplier or from the Performance Bond or file a claim against the supplier.

#### **21.0 Statutory variation in Taxes and Duties**

The total order value shall be adjusted on account of any variations in Statutory Levies imposed by Competent Authorities by way of fresh notification(s) within the stipulated delivery period only. However, in case of reduction in taxes, duties and levies, the benefits of the same shall be passed on to BUYER.

#### **Force Majeure**

##### **General**

An "Event of Force Majeure" shall mean any event or circumstance not within the Reasonable control directly or indirectly, of the Party affected, but only if and to the extent that:

- (i) Such event or circumstance materially and adversely affects the ability of the affected Party to perform its obligations under this Contract, and the affected Party has taken all reasonable precautions, due care and reasonable alternative measures in order to



Prevent or avoid the effect of such event on the affected party's ability to perform its obligations under this Contract and to mitigate the consequences thereof.

- (ii) For the avoidance of doubt, if such event or circumstance would not have materially and adversely affected the performance of the affected party had such affected party followed good industry practice, such event or circumstance shall not constitute force majeure.
- (iii) Such event is not the direct or indirect result of the failure of such Party to perform any of its obligations under this Contract.
- (iv) Such Party has given the other Party prompt notice describing such events, the effect thereof and the actions being taken in order to comply with above clause.

Specific Events of Force Majeure subject to the provisions of above clause, Events of Force Majeure shall include only the following to the extent that they or their consequences satisfy the above requirements:

- (i) The following events and circumstances:
  - a) Effect of any natural element or other acts of God, including but not limited to storm, flood, earthquake, lightning, cyclone, landslides or other natural disasters.
  - b) Explosions or fires
- (ii) War declared by the Government of India, provided that the ports at Mumbai are declared as a war zone.
  - i. Dangers of navigation, perils of the sea.

Notice of Events of Force Majeure If a force majeure event prevents a party from performing any obligations under the Contract in part or in full, that party shall:

- i)** Immediately notify the other party in writing of the force majeure events within 7(seven) working days of the occurrence of the force majeure event
- ii)** Be entitled to suspend performance of the obligation under the Contract which is affected by force majeure event for the duration of the force majeure event.
- iii)** Use all reasonable efforts to resume full performance of the obligation as soon as practicable
- iv)** Keep the other party informed of all such efforts to resume full performance of the obligation on a regular basis.
- v)** Provide prompt notice of the resumption of full performance or obligation to the other party.

Mitigation of Events of Force Majeure Each Party shall:

- Make all reasonable efforts to prevent and reduce to a minimum and mitigate the effect of any delay occasioned by an Event of Force Majeure including recourse to alternate methods of satisfying its obligations under the Contract;
- Use its best efforts to ensure resumption of normal performance after the termination of any Event of Force Majeure and shall perform its obligations to the maximum extent practicable as agreed between the Parties; and
- Keep the other Party informed at regular intervals of the circumstances concerning the event of Force Majeure, with best estimates as to its likely continuation and what measures or contingency planning it is taking to mitigate and or terminate the Event of Force Majeure.

Burden of Proof In the event that the Parties are unable in good faith to agree that a Force Majeure event has occurred to an affected party, the parties shall resolve their



Dispute in accordance with the provisions of this Agreement. The burden of proof as to whether or not a force majeure event has occurred shall be upon the party claiming that the force majeure event has occurred and that it is the affected party.

Termination for Certain Events of Force Majeure. If any obligation of any Party under the Contract is or is reasonably expected to be delayed or prevented by a Force Majeure event for a continuous period of more than 3 months, the Parties shall promptly discuss in good faith how to proceed with a view to reaching a solution on mutually agreed basis. If a solution on mutually agreed basis cannot be arrived at within a period of 30 days after the expiry of the period of three months, the Contract shall be terminated after the said period of 30 days and neither Party shall be liable to the other for any consequences arising on account of such termination.

Limitation of Force Majeure event. The Supplier shall not be relieved of any obligation under the Contract solely because cost of performance is increased, whether as a consequence of adverse economic consequences or otherwise.

Extension of Contract Period due to Force Majeure event The Contract period may be extended by mutual agreement of Parties by way of an adjustment on account of any period during which an obligation of either Party is suspended due to a Force Majeure event.

Effect of Events of Force Majeure. Except as otherwise provided herein or may further be agreed between the Parties, either Party shall be excused from performance and neither Party shall be construed to be in default in respect of any obligations hereunder, for so long as failure to perform such obligations shall be due to and event of Force Majeure."

### **23.0 Transfer and Sub-Letting**

**23.01** The Supplier shall not sublet, transfer, assign or otherwise part with the Contract or any part thereof, either directly or indirectly, without prior written permission of the Purchaser.

### **24.0 Recoveries**

**24.01** Whenever under this contract any money is recoverable from and payable by the bidder, the purchaser shall be entitled to recover such sum by appropriating in part or in whole by detecting any sum due to which any time thereafter may become due from the supplier in this or any other contract. Should the sum be not sufficient to cover the full amount recoverable the bidder shall pay to the purchaser on demand the remaining?

### **25.0 Waiver**

Failure to enforce any condition herein contained shall not operate as a waiver of the condition itself or any subsequent breach thereof.

### **Indemnification**

Notwithstanding contrary to anything contained in this RFQ, Supplier shall at his costs and risks make good any loss or damage to the property of the Purchaser and/or the other Supplier engaged by the Purchaser and/or the employees of the Purchaser and/or employees of the other Supplier engaged by the Purchaser whatsoever arising out of the negligence of the Supplier while performing the obligations

**SECTION – IV:****QUANTITY AND DELIVERY REQUIREMENT**

<b>Sl. No.</b>	<b>Item Description</b>	<b>Technical Specification</b>	<b>Estimated Cost</b>	<b>Qty.</b>	<b>Delivery at</b>
<b>1</b>	SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 3Cx150 SQ.MM	BSES-TS-HTAB-R0	Rs 1.54 Crores	15 KM	New Delhi Stores
<b>2</b>	SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 1CX95 SQ.MM		Rs 1.46 Crores	35 KM	New Delhi Stores



**SECTION – V**

**TECHNICAL SPECIFICATION (TS)**






**SUPPLY OF 11KV XLPE INSULATED ALUMINIUM  
CONDUCTOR AB CABLE OF SIZE 3Cx150 SQ.MM & 1C  
X 95 SQ.MM**

**NIT NO CMC/BR/23-24/RB/PR/FH/1093  
DT 25.01.2023**



Technical Specification of  
11 kV HT Aerial Bunched Cable

Specification no – BSES-TS-14-HTAB-R0

Rev:	0	
Date:	01 Apr 2022	
Prepared by	Gautam Deka	 01/04/22
	Pronab Bairagi	 01/04/2022
	Abhishek Vashistha	 11/4/22
Reviewed by	Puneet Duggal	
	Amit Tomar	 01/04/2022
Approved by	Gaurav Sharma	
	K. Sheshadri	 01/04/22.

**TABLE OF CONTENT**

1.0	SCOPE .....	3
2.0	CODES & STANDARDS .....	3
3.0	SERVICE CONDITIONS .....	4
4.0	CABLE DESIGN FEATURES .....	4
5.0	PACKING, SHIPPING, HANDLING AND STORAGE.....	7
6.0	QUALITY ASSURANCE PLAN, INSPECTION AND TESTING.....	8
7.0	DEVIATIONS .....	9
8.0	DOCUMENT SUBMISSION.....	9
9.0	ANNEXURE A - TECHNICAL PARTICULARS .....	10
10.0	GUARANTEED TECHNICAL PARTICULARS (DATA BY SUPPLIER).....	11

**1.0 SCOPE**

1.1	Scope	Design, manufacturing, testing at manufacturer's works, packing, transportation and delivery at site and submission of complete documentation for 11KV grade AB Cable as per following configurations.
	a. Three core cable	3CX150 sq mm (phase) + 150 sq mm (messenger)
	b. Single core cable	1CX95 sq mm (phase) + 95 sq mm (messenger)

**2.0 CODES & STANDARDS**

Materials and methods used in the manufacture of 11kv AB cable shall conform to the latest edition of all applicable parts of following codes & standards including amendments

**Indian Standards:-**

	Indian electricity act & Indian Electricity Rules
IS:8130 -1984	Conductors for Insulated electric Cables and flexible chords.
IS-398 (Part-IV) -1994	Aluminum Alloy Conductors
IS-14255-1995	Aerial Bunched Cables for working voltages up to and including 1100 Volts- specification
IS 5831-1984	PVC insulation and sheath of electric cable
IS 7098-2-1985	Cross linked Polyethylene insulated PVC sheathed cables
IS 10810-1984	Method of test for cable
IS-10418-1982	Specification for Drums for Electric Cables
IS-3975-1999	Mild steel wires strips and tapes for armoring cables.
IS-10462 Part1	Fictitious calculation for determination of dimensions of protective coverings of cables.

**International Standards: -**

IEC 60228	Conductor for insulation cable.
IEC 60811	Common test method for insulating and sheathing materials of electric cable and optical cable
IEC 60502-2	Extruded solid electrical insulated power cables for rated voltages from 1 KV to 30 KV
IEC 60811 , Part 1 to 5	Common test methods for insulating and sheathing materials of electric cable.
IEC 855, Part 1 to 3	Electric test method for electric cable.
NFC: 33-209	Bundle assemble cores for overhead system

**3.0 SERVICE CONDITIONS**

S No.	Parameter	BSES Requirement	Bidder's Reply
3.1	Max Ambient Temperature	50 deg C	
3.2	Max Daily average ambient temp	40 deg C	
3.3	Min Ambient Temp	0 deg C	
3.4	Maximum Humidity	95%	
3.5	Minimum Humidity	10%	
3.6	Maximum annual rainfall	750 mm	
3.7	Average no of rainy days per annum	60	
3.8	Rainy months	June to Oct	
3.9	Altitude above MSL	300 M	
3.10	Seismic Zone	IV	

**4.0 CABLE DESIGN FEATURES**

S No.	Particular	Requirement
4.1	Conductor	
4.1.1	Type	Electrolytic grade stranded aluminum conductor.
4.1.2	Grade	H4 as per IS:8130 / 1984
4.1.3	Flexibility class	Class -2
4.1.4	Shape of conductor	Compacted circular
4.2	Conductor screen	
4.2.1	Type of material	Extruded semi conducting material suitable for continuous operating conductor temperature of 90 deg.C
4.2.2	Minimum thickness	Refer to Annexure – A.
4.2.3	Make of compound	Dow / Borealis / Hanwha
4.3	Insulation	
4.3.1	Type	a. Extruded WTR- XLPE (Cross-Linked Poly-Ethylene) insulation b. Uniform thickness of insulation shall be within the permissible values as per IEC standards; eccentricity check shall be carried out to ensure this.
4.3.2	Nominal and minimum thickness	Refer to Annexure – A
4.3.3	Make of compound	Dow / Borealis / Hanwha
4.4	Insulation Screen	
4.4.1	Non Metallic Insulation screen	
4.4.1.1	Type	a. Extruded freely strippable semi conducting material which should not require application of heat for it's removal

**TECHNICAL SPECIFICATION FOR 11 KV HTAB CABLE**

<b>S No.</b>	<b>Particular</b>	<b>Requirement</b>
		b. Text "Do not Heat - Freely Strippable" to be printed on insulation screen (at every 600 mm interval).
4.4.1.2	Minimum thickness	Refer to Annexure – A
4.4.1.3	Make of compound	Dow / Borealis / Hanwha
4.4.2	Bedding Tape	Semi conducting bedding tape shall be applied over nonmetallic insulation screen.
4.4.2.1	Minimum thickness	Refer to Annexure –A
4.4.3	Metallic insulation screen	
4.4.3.1	Type	Aluminum wire with minimum 90% coverage, helically applied over bedding tape.
4.4.3.2	Minimum thickness	<p>Metallic screen of individual core should be suitable to carry the following minimum amount of fault current:</p> <p>a. For single phase HTAB – 8 kA for 1 sec</p> <p>b. For three phase HTAB – 10 kA for 1 sec</p> <p>Diameter of armour wire: For 1Cx95 sq mm &amp; 3Cx150 sq mm cable – 2.3 +/- 0.1 mm</p> <p>Calculation fulfilling short circuit requirement shall be submitted by bidder.</p>
4.4.3.3	Rubberized Cotton Tape	Rubberized cotton tape with min. thickness of 0.15 mm shall be provided over metallic screen.
4.5	Outer sheath	
4.5.1	Type	Extruded outer sheath of polyethylene (PE), Grade – ST-7 to IEC: 60502-2
4.5.2	Colour of sheath	Black
4.5.3	Thickness	As per Annexure-A
4.5.4	Immunity against UV exposure	Outer sheath shall be suitable for overhead application and shall be immune to UV exposure.
4.5.5	Carbon black content	2.5% +/-0.5%
4.5.6	Embossing on outer sheath	Outer sheath shall have following embossing.
		a. The voltage designation

**TECHNICAL SPECIFICATION FOR 11 KV HTAB CABLE**

<b>S No.</b>	<b>Particular</b>	<b>Requirement</b>
		<ul style="list-style-type: none"> <li>b. Type of construction, number and size of phase, and messenger conductor</li> <li>c. Type of insulation and outer sheath, i.e XLPE / PE ST 7</li> <li>d. Manufacturer name / Trade name</li> <li>e. Name of buyer</li> <li>f. Month and year of manufacture</li> <li>g. Lot no and batch no.</li> <li>h. Purchase Order Number and Date</li> <li>i. Individual Drum number and Progressive length marking shall be indelibly printed on outer sheath of single core HTAB cable</li> </ul>
4.6	Messenger conductor	
4.6.1	Type	<ul style="list-style-type: none"> <li>a. Aluminum alloy (Al + Mg + Si) stranded conductor confirming to IS: 398, Part-IV. Wires shall be heat treated to get desired mechanical &amp; electrical properties.</li> <li>b. Extruded outer sheath of PE Grade – ST 7 with carbon black content 2.5% +/- 0.5 %</li> <li>c. Colour of outer sheath on messenger shall be Black with thickness as per Annexure-A.</li> </ul>
4.6.2	Shape	Smooth round surface to avoid damage of outer sheath.
4.6.3	Capacity	Messenger conductor should carry the weight of aerial bunched cables under specific site condition.
4.6.4	Minimum breaking load of messenger	Refer to Annexure – A.
4.7.0	Sealing of cable end	Both end of each phase core shall be sealed by means of non-hygroscopic sealing materials so as to protect the cable from outside moisture during transit, storage and laying.
4.8	Cable manufacturing process	
4.8.1	Curing process of XLPE	Dry cure only
4.8.2	Extrusion	Conductor screen, insulation and insulation screen shall be extruded

**TECHNICAL SPECIFICATION FOR 11 KV HTAB CABLE**

<b>S No.</b>	<b>Particular</b>	<b>Requirement</b>
		simultaneously, in a single one time process (i.e. as a triple-head extrusion) to ensure homogeneity of layers over the conductor, and absence of voids.
4.8.3	Laying up	Phase cores twisted around the messenger
4.8.4	Assembly lay length	Maximum 40 times of sheath phase core diameter.
4.8.5	Core identification	By Red, Yellow Blue colored strips co-extruded in outer sheath as a single layer.  Width of colored strip – 3 to 5 mm Depth of colored strip – 0.2 mm (max)
4.9.0	Standard drum length and tolerance	
4.9.1	3CX150 sqmm (Ph.) + 150sqmm (M)	500 meters +/- 5%
4.9.2	1X95 sqmm (Ph) + 95 sqmm (M)	1000 meters +/- 5%
4.10.0	Short length of cable	a. Manufacturer shall be required to take prior approval from CES BSES for processing of any short length.  b. For 150 sqmm and 95 sqmm cable minimum acceptable short length shall be 300 meters & 500 respectively. Only one short length per lot is acceptable.

**5.0 PACKING, SHIPPING, HANDLING AND STORAGE**

<b>S No.</b>	<b>Particular</b>	<b>Requirement</b>
5.1	Drum Identification labels.	a. Drum identification number
		b. cable voltage grade
		c. cable construction
		d. Number of core and cross sectional area.
		e. Cable quantity
		f. Purchase order number with date and SAP item code
		g. Total weight of cable and drum
		h. Manufacturer's and buyer's name
		i. Month and year of manufacturing
		j. Direction of rotation of drum

**TECHNICAL SPECIFICATION FOR 11 KV HTAB CABLE**

<b>S No.</b>	<b>Particular</b>	<b>Requirement</b>
5.2	Shipping information	The seller shall give complete shipping information concerning the weight, size of each packing.
5.3	Transit damage	The seller shall be responsible for any transit damage due to improper packing.
5.4	Type of drum	a. Steel / wooden drums (wooden drums shall have M.S spindle plate with nut-bolts as per relevant IEC/IS, b. The drum shall be of such construction as to assure delivery of cable at site free from displacement and damage and should be able to withstand all stresses during handling in transit and laying. The cable drum shall be suitable for wheel mounting.
5.4.1	For wooden drum	a. All wood component of drum shall be properly seasoned, sound and free from any defect. Wood preservative treatment shall be applied. b. Bolts screws, nails etc if used in the construction of drums shall be counter sunk, so that heads are below the surface or the flange.
5.4.2	For steel drum / ferrous part of wooden drum	Ferrous metal shall be treated with suitable rust preventive finish or coating to minimize rusting during storage.

**6.0 QUALITY ASSURANCE PLAN, INSPECTION AND TESTING**

<b>S No.</b>	<b>Particular</b>	<b>Requirements</b>
6.1	Quality Assurance Plan	QAP Shall be submitted by vendor for approval. Inspection and testing of the material shall be carried out accordingly.
6.2	Type test	a. Cables must be of type tested as per relevant IS/IEC/ASTM. Type test conducted from CPRI or ERDA will be treated as valid. b. Type test reports shall be submitted for the type, size & rating of cable offered along with bid. c. UV resistance test to be carried out on one sample per PO from NABL accredited laboratory as per ASTM standard. Minimum retention in properties of tensile strength and elongation shall be 80% after exposure of 21 day.

S No.	Particular	Requirements
		d. For UV exposure test; If the manufacturer's lab is accredited by govt. /authorized body then it shall be acceptable for testing.
6.3	Routine test	Each drum length of cable shall be subjected to the tests as mentioned in IS 7098 part -2
6.4	Acceptance Tests	The sampling & acceptance tests shall be conducted, as per IS 7098 Part-2 and approved QA plan, for each lot of cable during the inspection of lot at manufacturer's works.
6.5	Additional Tests	Following additional tests shall also to be carried out during acceptance testing on one sample from each offered lot: a. Wafer boil test for checking integrity of semi-conducting layer. b. Void and contamination test for insulation. c. Percentage of carbon black contents at outer sheath.

## 7.0 DEVIATIONS

7.1.0	Deviations from specification	Deviations from this Specification shall be stated in writing with the tender by reference to the Specification clause / GTP and a description of the alternative offer. In absence of such a statement, it will be assumed by the buyer that the seller complies fully with this specification.
-------	-------------------------------	--

## 8.0 DOCUMENT SUBMISSION

Document/Drawing submission shall be as per the matrix given below:

- i. All documents/drawings shall be provided in soft copy only in returnable Pen drives
- ii. Language of the documents shall be English only.
- iii. Incomplete submission shall be liable for rejection.
- iv. Document check sheet compliance shall be the first sheet for each submission stage i.e. Technical bid, Drawing Approval, Pre Dispatch.
- v. No submission is acceptable without check list compliance.
- vi. Deficient/ improper document/ drawing submission shall be liable for rejection.
- vii. Order of documents shall be strictly as per the check list.
- viii. Any drawing not included in the below table but necessary for detailed engineering shall be deemed to be included in bidder's scope.

S No.	Description	Bid	Approval	Pre Dispatch
8.1	Guaranteed Technical Particulars (GTP)	Required	Required	
8.2	Deviation Sheet, if any	Required	Required	

**TECHNICAL SPECIFICATION FOR 11 kV HTAB CABLE**

<b>S No.</b>	<b>Description</b>	<b>Bid</b>	<b>Approval</b>	<b>Pre Dispatch</b>
8.3	Detailed cross sectional drawing of cable	Required	Required	
8.4	Dimensional drawing of Cable Drum		Required	
8.5	Type test reports for the offered type and rating of cable	Required		
8.6	Make of Raw Materials	Required	Required	
8.7	Cable de-rating factors	Required	Required	
8.8	Manufacturer's Quality Assurance Plan		Required	
8.9	Program for production and testing/ Production and Testing Timeline		Required	
8.10	Detailed installation & commissioning instructions		Required	
8.11	Test certificates of all raw materials			Required
8.12	Inspection and routine test reports, carried out in manufacturer's works			Required

**9.0 ANNEXURE A - TECHNICAL PARTICULARS**

<b>Sl. No.</b>	<b>Descriptions</b>	<b>3CX 150 sqmm (Ph) + 150 sqmm (M) AB Cable</b>	<b>1CX95 sqmm (Ph.) + 95 sqmm (M) AB Cable</b>
9.1	Conductor		
9.2	Shape	Compacted Circular	Compacted Circular
9.3	Maximum DC resistance at 20° C ( $\Omega$ /km)	0.206	0.320
9.4	Minimum thickness of conductor screen	0.5 mm	0.5 mm
9.5	Insulation on Phase conductor		
9.5.1	Minimum thickness	3.14 mm	3.14 mm
9.5.2	Nominal thickness	3.60 mm	3.60 mm
9.6	Insulation screen on Phase conductor		
9.6.1	Minimum thickness of non-metallic screen	0.5 mm	0.5 mm

**TECHNICAL SPECIFICATION FOR 11 KV HTAB CABLE**

Sl. No.	Descriptions	3CX 150 sqmm (Ph) + 150 sqmm (M) AB Cable	1CX95 sqmm (Ph.) + 95 sqmm (M) AB Cable
9.6.2	Minimum thickness of semi conducting Bedding Tape	0.2 mm	0.2 mm
9.7	Metallic Screen	Al Wire of dia 2.3 +/- 0.1 mm	Al Wire of dia 2.3 +/- 0.1 mm
9.8	Minimum thickness of rubberized cotton tape Tape	0.15mm	0.15mm
9.9	Outer sheath on Phase Conductor	PE ST-7	
9.9.1	Minimum thickness	1.4 mm	1.4 mm
9.9.2	Nominal thickness	2.0 mm	2.0 mm
9.10	Messenger		
9.10.1	Number of strands	19	7
9.10.2	Minimum diameter of strands	3.15	4.26
9.11	Minimum breaking load	43.50 KN	26.3 KN
9.12	Nominal conductor diameter	15.75 mm	12.78 mm
9.13	Maximum DC resistance at 20 <sup>o</sup> C	0.229 Ω/km	0.357 Ω/km
9.14	Minimum elongation	4% on a gauge length of 200mm	4% on a gauge length of 200mm
9.15	Outer sheath over Messenger	PE ST-7	
9.15.1	Nominal thickness	1.8 mm	1.8 mm

**10.0 GUARANTEED TECHNICAL PARTICULARS (DATA BY SUPPLIER)**

Sr. No.	Description	Buyer's requirements	Vendor's data
10.1	Name of manufacturer		
10.2	Guarantee Period		
10.3	Type of cable		
10.4	Application standards	IS: 7098, P-2 ; IS: 398, P-4 & IEC 60502	
10.5	Voltage grade	6.35 / 11 KV	
10.6	Number of phase	3 or 1	
10.7	Conductor		
10.7.1	Type of conductor	EC grade aluminum, grade –H4	
10.7.2	Flexibility class	Class -2	
10.7.3	Shape of conductor	Stranded, compacted and circular	

Sr. No.	Description	Buyer's requirements	Vendor's data
10.7.4	Minimum number of strands	----- nos (min.)	
10.7.5	Nominal diameter of strands before compaction	----- mm (nom)	
10.7.6	Minimum diameter of strands before compaction	----- (Min.)	
10.7.7	Nominal cross sectional area of conductor	As per annexure – A	
10.7.8	Diameter over bare conductor	---- mm	
10.7.9	Maximum DC resistance at 20 Deg.C	As per annexure – A	
10.7.10	Lay ratio and direction of lay of wires		
10.7.10.1	Outside layer		
10.7.10.2	Layer immediately beneath outside layer		
10.7.10.3	Inner most layer of conductor with three aluminum wires layer		
10.8	Conductor screening		
10.8.1	Type of material	Extruded semi conducting XLPE compound	
10.8.2	Minimum thickness	As per annexure – A	
10.8.3	Make of compound		
10.8.4	Grade of compound		
10.9	Insulation on Phase conductor		
10.9.1	Type of insulation	As per Cl. 4.3.1	
10.9.2	Thickness		
a.	Nominal	As per annexure – A	
b.	Minimum	As per annexure – A	
10.9.3	Diameter over insulation	---- mm (approx.)	
10.9.4	Make of compound		
10.9.5	Grade of compound		
10.10	Insulating screen on phase conductor		
10.10.1	Non-metallic screen		
10.10.1.1	Type of material	Freely strippable type Extruded semi conducting compound	
10.10.1.2	Minimum thickness of screen	As per annexure – A	
10.10.1.3	Make of compound		
10.10.1.4	Grade of compound		
10.10.2	Bedding Tape	Semiconducting bedding tape	
10.10.2.1	Minimum thickness	0.2mm	
10.10.3	Metallic screen		

TECHNICAL SPECIFICATION FOR 11 KV HTAB CABLE

Sr. No.	Description	Buyer's requirements	Vendor's data
10.10.3.1	Type	Aluminum wire	
10.10.3.2	Diameter	As per annexure – A	
10.10.4	Rubberized Cotton Tape	0.15mm	
10.10.4.1	Percentage overlapping		
10.11	Outer sheath on Phase conductor		
10.11.1	Type of material	PE type ST -7 to IEC 60502	
10.11.2	Color of outer sheath	Black	
10.11.3	Thickness		
a.	Minimum	As per annexure – A	
b.	Nominal	As per annexure – A	
10.11.4	Diameter over core	----- mm (approx.)	
10.11.5	Carbon black content	2.5 % +/-0.5%	
10.11.6	Core Identification	By Red, Yellow Blue colored strips extruded in outer sheath as a single sheath.  a. Width of strip b. Depth of strip	
10.12	Bare messenger conductor		
10.12.1	Material and IS standard	Aluminum alloy to IS:398, Part-4	
10.12.2	Conductor shape	Stranded, compacted & circular	
10.12.3	Nominal cross sectional area	As per annexure – A	
10.12.4	Minimum number of strands	As per annexure – A	
10.12.5	Nominal diameter of strands before compaction	-----mm	
10.12.6	Minimum diameter of strands before compaction	----- mm	
10.12.7	Diameter of conductor	----- mm	
10.12.8	Lay ratio and direction of lay		
10.12.8.1	Outside layer		
10.12.8.2	Layer immediately beneath outside layer		
10.12.9	Maximum elongation	4 %	
10.12.10	Minimum Breaking load of conductor	As per annexure – A	
10.12.11	Maximum DC resistance at 20 deg.C	As per annexure – A	
10.12.12	Modulus of elasticity	----- kh /sqcm	
10.12.13	Co-efficient of linear expansion	----- / deg.C	

TECHNICAL SPECIFICATION FOR 11 KV HTAB CABLE

Sr. No.	Description	Buyer's requirements	Vendor's data
10.12.14	Chemical composition	As per manufacturer standard.	
10.12.14.1	Aluminum	----- %	
10.12.14.2	Magnesium	----- %	
10.12.14.3	Silicon	----- %	
10.12.15	Outer sheath over messenger conductor		
10.12.15.1	Type of material	PE type ST -7 to IEC 60502	
10.12.15.2	Color of outer sheath on messenger	Black	
10.12.15.3	Thickness		
a.	i. Minimum	As per annexure – A	
b.	ii. Nominal	As per annexure – A	
10.13.1	Assembly lay length	----- mm	
10.13.2	Lay direction	RH / LH	
10.13.3	Recommended minimum bending radius	----- mm	
10.13.4	Approx. overall diameter of cable	----- mm	
10.14.0	Drums		
10.14.1	Type of drum	Steel / wooden (non returnable)	
10.14.2	Anti termite treatment on wooden drums	Provided	
10.14.3	Standard drum length with tolerance		
10.14.4	Short length		
10.15.0	Weight		
10.15.1	Approx. weight of cable	----- kg / km	
10.15.2	Weight of empty drum	----- kg.	
10.15.3	Weight of cable with drum	----- kg.	
10.16.0	Current rating		
10.16.1	Continuous current rating capacity in air at 40 deg.C	----- amps	
10.16.2	Derating factor for following ambient temperature-		
a.	At 30 deg.C		
b.	At 35 deg.C		
c.	At 40 deg.C		
d.	At 45 deg.C		
e.	At 50 deg.C		
10.17.0	Maximum conductor temperature		
10.17.1	Continuous operation.	----- Deg.C	

Sr. No.	Description	Buyer's requirements	Vendor's data
10.17.2	short circuit	----- Deg.C	
10.18.0	Short circuit capacity for one seconds		
10.19.0	Electrical parameter at maximum operating temperature		
10.19.1	AC resistance	----- $\Omega$ /km	
10.19.2	Reactance at 50 Hz.	----- $\Omega$ /km	
10.19.3	Positive sequence Impedance	----- $\Omega$ /km	
10.19.4	Negative sequence Impedance	----- $\Omega$ /km	
10.19.5	Zero sequence impedance	----- $\Omega$ /km	
10.19.6	Capacitance	----- $\mu$ f / km	
10.20.0	Identification of phase core		
10.21.1	Embossing on outer sheath		
10.21.2	Font size of letters	----- mm	
10.21.3	Individual Drum number provided on outer sheath by	Embossing/ Indelible Printing	
10.22.0	Process of cross linking of poly ethylene	Dry	
10.23.0	Type test report submitted	Yes / no ( if yes-specify report number)	
10.24.0	Sectional drawing of cable – submitted?	Yes / no. ( drg. No.)	
10.25.0	Drawing of drum – submitted?	Yes / no (drg. No.	

Note: Bidder shall furnish the GTP format along with acceptance to all clauses mentioned in the specification. Bidder shall not change the format of GTP or clause description. Bidder to submit duly filled GTP and acceptance to every clause of the specification.



**ANNEXURE -I**

**PRICE FORMAT**

<b>ITEM DESCRIPTION</b>	<b>QTY</b>	<b>UoM</b>	<b>EX- WORKS RATE PER KM</b>	<b>UNIT FREIGHT</b>	<b>GST</b>	<b>UNIT LANDED</b>	<b>TOTAL LANDED COST</b>
SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 3Cx150 SQ.MM	15	KM					
SUPPLY OF 11KV XLPE INSULATED ALUMINIUM CONDUCTOR AB CABLE OF SIZE 1CX95 SQ.MM	35	KM					



**ANNEXURE -II**

**BID FORM**

To

Head of Department  
Contracts & Material  
Deptt. BSES Rajdhani  
Power Ltd 1<sup>st</sup> Floor, C  
Block  
BSES Bhawan, Nehru  
Place New Delhi  
110019

Sir,

1 We understand that BRPL is desirous of procuring of..... in its licensed distribution network area in Delhi

2 Having examined the Bidding Documents for the above named works, we the undersigned, offer to deliver the goods in full conformity with the Terms and Conditions and technical specifications as may be determined in accordance with the terms and conditions of the contract.

3 If our Bid is accepted, we undertake to deliver the entire goods as) as per delivery schedule mentioned in Section IV from the date of award of purchase order/letter of intent.

4 If our Bid is accepted, we will furnish a performance bank guarantee for an amount of 10% (Ten)percent of the total contract value for due performance of the Contract in accordance with the Terms and Conditions.

5 We agree to abide by this Bid for a period of 120..... days from the due date of bid submission and it shall remain binding upon us and may be accepted at any time before the expiration of that period.

6 We declare that we have studied the provision of Indian Laws for supply of equipments /materials and the prices have been quoted accordingly.

7 Unless and until Letter of Intent is issued, this Bid, together with your written acceptance thereof, shall constitute a binding contract between us.

8 We understand that you are not bound to accept the lowest, or any bid you may receive.

9 There is provision for Resolution of Disputes under this Contract, in accordance with the Laws and Jurisdiction of Contract.

Dated this..... day of .....2023

Signature..... In the capacity of .....

.....duly authorized to sign for and on behalf of

(IN BLOCK CAPITALS).....



### **ANNEXURE -III**

#### **ACCEPTANCE FORM FOR PARTICIPATION IN REVERSE AUCTION EVENT**

(To signed & stamped by the bidder along with bid)

BSES Rajdhani Power Ltd (BRPL) intends to use reverse auction through SAP-SRM tool as an integral part of entire tendering process. All bidders who are techno-commercially qualified on the basis of tender requirements shall participate in the reverse auction.

The following terms and conditions are deemed as accepted by the bidder on participation in the bid:-

1. In case of bidding through Internet medium, bidders are advised to ensure availability of all associated infrastructure as required to participate in the reverse auction event. Inability to bid due to telephone glitch, internet response issues, software & hardware hangs/failures, power failures or any other reason shall not be the responsibility of BRPL.
2. In case bidder fails to participate in the reverse auction event due to any reason whatsoever, it shall be presumed that the bidder has no further discounts to offer and the initial bid submitted by them as a part of tender shall be considered as bidder's Final No Regret offer. Any off-line price bids received from a bidder in lieu of non-participation in the reverse auction event shall be rejected by BRPL.
3. The bidder is advised to understand the auto bid process to safeguard themselves against any possibility of non-participation in the reverse auction event.
4. The bidder shall be prepared with competitive price quotes during the day of reverse auction event.
5. The prices quoted by bidder in reverse auction event shall be on FOR Landed cost BRPL Store/site basis inclusive of all relevant taxes, duties, levies, transportation charges etc.
6. The prices submitted by the bidder during reverse auction event shall be binding on the bidder.
7. The bidder agrees to non-disclosure of trade information regarding bid details e.g. purchase, identity, bid process/technology, bid documentation etc.
8. BRPL will make every effort to make the bid process transparent. However award decision of BRPL will be final and binding on the bidder.
9. The prices submitted during reverse auction event shall be binding on the bidder.
10. No request for Time extension of the reverse auction event shall be considered by BRPL.



**ANNEXURE -IV**

FORMAT FOR EMD BANK GUARANTEE

*(To be issued in a Non Judicial Stamp Paper of Rs.50/-purchased in the name of the bank)*

Whereas [*name of the Bidder*] (herein after called the "Bidder") has submitted its bid dated [*date of submission of bid*] for the supply of [*name and/or description of the goods*] (here after called the "Bid").

KNOW ALL PEOPLE by these presents that WE [*name of bank*] at [*Branch Name and address*], having our registered office at [*address of the registered office of the bank*] (herein after called the "Bank"), are bound unto BSES Rajdhani Power Ltd., with it's Corporate Office at BSES Bhawan Nehru Place, New Delhi -110019, (herein after called —the "Purchaser") in the sum of ..... (Rupees.....only) for which payment well and truly to be made to the said Purchaser, the Bank binds itself, its successors, and assigns by these presents.

Sealed with the Common Seal of the said Bank this

\_\_\_\_\_ day of \_\_\_\_\_ 20

THE CONDITIONS of this obligation are:

If the Bidder withdraws its Bid during the period of bid validity specified by the Bidder on the Bid Form; or

2. If the Bidder, having been notified of the acceptance of its Bid by the Purchaser during the period of bid validity:

- (a) fails or refuses to execute the Contract Form ,if required; or
- (b) fails or refuses to furnish the performance security, In accordance with the Instructions to Bidders/ Terms and Conditions;

We undertake to pay to the Purchaser up to the above amount upon receipt of its first written demand, without the Purchaser having to substantiate its demand, provided that is its demand the purchaser will note that amount claimed by it is due to it, owing to the occurrence of one or both of the two condition(s), specifying the occurred condition or condition(s).

This guarantee will remain in force up to and including ONE TWENTY DAYS(120) days after the due date of submission bid, and any demand in respect thereof should reach the Bank not later than the above date.

(Stamp & signature of the bank)

Signature of the witness(s)

**ANNEXURE -V****COMMERCIAL TERMS AND CONDITIONS**

SI N	Item Description	AS PER BRSPL	BIDDER'S CONFIRMATIO
1	Validity	<b>120 days</b> from the date of offer.	
2	Price basis	a) <b>FIRM</b> , FOR Delhi store basis. Prices shall be inclusive of all taxes & duties, freight up to Delhistores. b) Unloading at stores shall be in vendor's scope	
3	Payment terms	100% payment within <b>45 days</b> after receipt of material at stores	
4	Delivery schedule	As per SECTION - IV	
5	Defect Liability period	60 months after commissioning or 66 months from the last date of dispatch, whichever is earlier	
6	Penalty for delay	1% per week of delay of undelivered units or part thereof subject to maximum of 10% of total PO value of undelivered units	
7	Performance Bank Guarantee	10% of total PO value valid for 24 months after commissioning or 30 months from the last date of dispatch, whichever is earlier plus 3 months towards claim period	

**Bidder should also furnish the below details for future communication:-**

<b>FOR TECHNICAL QUERY:</b>		
CONTACT PERSON & DESIGNATION	NAME	DESIGNATION
E-MAIL	MOBILE NO	TELEPHONE NO

<b>FOR COMMERCIAL QUERY:</b>		
CONTACT PERSON & DESIGNATION	NAME	DESIGNATION
E-MAIL	MOBILE NO	TELEPHONE NO



**ANNEXURE VI**

**NO DEVIATION SHEET**

SL NO	SL NO OF TECHNICAL SPECIFICATION	DEVIATIONS,IF ANY

**SIGNATURE & SEAL OF BIDDER**

**NAME OF BIDDER**



**ANNEXURE-VII**

**FORMAT FOR BACKUP OF SUPPLY & PERFORMANCE QUANTITY**

S.No	PO No	PO Date	PO Qty	Supplied		Customer	F.Y
				Qty.	Date		



### **CHECK LIST**

<b>SI No</b>	<b>Item Description</b>	<b>YES/NO</b>
1	INDEX	YES/NO
2	COVERING LETTER	YES/NO
3	BID FORM (UNPRICED) DULY SIGNED (1 nos. Original +1 nos. Photo Copy)	
4	BILL OF MATERIAL (UNPRICED) (1 nos. Original +1 nos. Photo Copy)	YES/NO
5	TECHNICAL BID (1 nos. Original +1 nos. Photo Copy)	YES/NO
6	ACCEPTANCE TO COMMERCIAL TERMS AND CONDITIONS	YES/NO
7	FINANCIAL BID (IN SEALED ENVELOPE – 1 ORIGINAL)	YES/NO
8	EMD IN PRESCRIBED FORMAT	YES/NO
9	DEMAND DRAFT OF RS 1180/- DRAWN IN FAVOUR OF	BSES RAJDHANI POWER LTD
10	POWER OF ATTORNEY/AUTHORISATION LETTER FOR SIGNING THE BID	
11	ACCEPTANCE FORM FOR REVERSE AUCTION	YES/NO
12	PLANT MANUFACTURING CAPACITY (CA CERTIFIED)	YES/NO
13	ANNUAL TURNOVER (CA CERTIFIED)	YES/NO
14	PERFORMANCE CERTIFICATE AS PER QR	YES/NO
15	SUPPLIED QUANTITY AS PER PQR	YES/NO
16	ISO Certification /Any other certification/Type test Report/BIS etc as per PQR	YES/NO
17	Quality Assurance /Organization Chart	YES/NO
18	Undertakings as per NIT	YES/NO
19	Technical Deviation	YES/NO
20	SUPPLIED/PERFORMANCE QTY AS PER QR ( IN ANNEXURE-VII) CA CERTIFIED	YES/NO
Note : The above document must be properly tagged with page nos.		