

Single Phase Meter With Box and MCB

- 1. BYPL is desirous to pilot of 'Single Phase Meter with Box and MCB' along with all required accessories e.g. cable glands etc.
- 2. Indicative drawing of the required solution is enclosed herewith for your reference.
- 3. This solution may be considered for bulk implementation after ascertaining results of the pilot.
- 4. **01 No samples** shall be submitted for the offered product with technical evaluation.
- 5. Following are the technical parameters of the solution:

SI	Item	Technical parameters
1	Meters	Specification No SPTWM_09_R5 (Rev 5) dated 16/11/2021.
2	Box	a. Specification No SPTWM_09_R5 (Rev 5) dated 16/11/2021.
		b. Access to MCB On and Off switch shall be provided from outside with
		sealable cover.
3	MCB	a. 63 A, Double pole, C Type, MCB.
		b. Approved Make: L&T, Schneider, ABB, Legrand, Havells.
		(Approval of any other make shall be taken from BYPL during technical
		evaluation stage.)

