

<b>BYPL NIT NO:</b>	CMC/BY/23-24/RS/SvS/VK/18 DT: 27.06.2023			
<b>Work:</b>	Construction of Electrical Vehicle (EV) charging substation building at Rajghat-1 DTC depot (D) Daryaganj, BSES Delhi			
<b>Subject:</b>	Reply of bidders queries			
Sl. No	NIT Clause Reference	Description as Per NIT & earlier corrigendums	Bidder's Query	BYPL's Reply
1	SECTION- V (Scope of work), Clause 11 -APPROVED MAKES Page No 93 of 139	Approved makes mentioned for different construction items.	1) Only one brand has been specified for the major items. Atleast 3-4 brands should be specified. 2) It shall be considered that brands specified may not be provide small quantities in delhi as these brands are not based in delhi 3) Brands like Pacific fire doors, navair international etc. are delhi based manufactures which provides doors to reputed projects.	Clause no 11: Approved Makes for following Sl No is revised as: >SL no 11: Dorma/ Ozone/Dorset. > SL no 22: Shaktimann/ Navair international/ Pacific fire ( subject to they shall submit the test certificate from CBRI for 2 hrs fire rating as per IS code) > SL no 23: Ozone / Jindal  For rest items Tender condition shall prevail. Bidders are requested to quote accordingly.
2	Section- I (RFQ) General, 1.3 Page No 11 of 139	Duration of work= 04 Month	We request you to please increase the time of completion of the work by 2 to 3 months	Tender conditions shall prevail. Bidders are requested to quote accordingly.