

**CORRIGENDUM-1, Dated: 12/07/2023**

<b>BYPL NIT NO:</b>		CMC/BY/23-24/RS/SvS/VK/21 DT: 04.07.2023		
<b>Work:</b>		Construction of Electrical Vehicle (EV) charging substation building at Seemapuri (Div.) Dilshad Garden, BSES Delhi		
<b>Subject:</b>		Reply of bidders queries		
Sl. No	NIT Clause Reference	Description as Per NIT & earlier corrigendums	Bidder's Query	BYPL's Reply
1	SECTION- V (Scope of work), Clause 11 -APPROVED MAKES Page No 93 of 139	Approved makes mentioned for different construction items.	<p>1) Only one brand has been specified for the major items. Atleast 3-4 brands should be specified.</p> <p>2) It shall be considered that brands specified may not be provide small quantities in delhi as these brands are not based in delhi</p> <p>3) Brands like Pacific fire doors, navair international etc. are delhi based manufactures which provides doors to reputed projects.</p>	<p>Clause no 11: Approved Makes for following Sl No is revised as:</p> <p>&gt;SL no 11: Dorma/ Ozone/Dorset.</p> <p>&gt; SL no 22: Shaktimann/ Navair international/ Pacific fire ( subject to they shall submit the test certificate from CBRI for 2 hrs fire rating as per IS code)</p> <p>&gt; SL no 23: Ozone / Jindal</p> <p>For rest items Tender condition shall prevail. Bidders are requested to quote accordingly.</p>
2	Section- I (RFQ) General, 1.3 Page No 11 of 139	Duration of work= 04 Month	We request you to please increase the time of completion of the work by 2 to 3 months	Tender conditions shall prevail. Bidders are requested to quote accordingly.